

Legislative Assembly Question on Notice 7307

[Tabled Paper No.]

Western Power Maintenance Program	
Preventative routine maintenance (transmission)	2011/12 (\$M)
Substation primary plant maintenance	4.9
Substation HV equipment testing	1.9
Secondary equipment maintenance	2.2
Substation maintenance buildings and grounds	1.8
Substation battery maintenance and inspection	0.6
Insulator siliconing	1.3
Pole top inspection and line patrols	1.1
Pole base inspections and treatment	1
Other	4.3
Sub total	19.1
Preventative routine maintenance (distribution)	
Power pole bundled inspections	21.2
Bulk globe replacement	8.9
Fuse and metal pole inspections	10.4
Vegetation inspections	3.6
Insulator siliconing	3.1
Ground mounted switchgear / substation inspections	5.4
Other	1.6
Sub total	54.2
Preventative condition maintenance (transmission)	
Line easement vegetation maintenance	4.0
Overhead lines maintenance	3.5
Plant and building refurbishment	0.9
Substation primary plant maintenance	1

Underground cable maintenance	0.4
Other	0.5
Sub total	10.3
Preventative condition maintenance (distribution)	
Line easement vegetation maintenance	26.3
Pole maintenance	19.6
Earthing maintenance	1.7
Ground mounted switchgear maintenance	2.5
Minor asset replacement	1.6
Other	2.9
Sub total	54.6
Corrective emergency maintenance (transmission)	2011/12
Substation primary plant maintenance	0.9
Line maintenance	0.8
Secondary equipment maintenance	0.1
Sub total	1.8
Corrective emergency maintenance (distribution)	
Primary response	58.3
Storms	11.2
Streetlight faults	9.7
Emergency response generator deployment	3.4
Truck items and minor consumables	2.9
Post-fault line patrols	0.6
Sub total	86.1
Corrective deferred maintenance (transmission)	
Substation primary plant maintenance	5.2

Substation site maintenance	1.2
Environmental cleanup	0.9
Protection equipment maintenance	0.3
DC systems maintenance	0.6
Other	0.8
Sub total	9
Corrective deferred maintenance (distribution)	
Emergency follow-up overhead maintenance	4.1
Emergency follow-up underground maintenance	3.4
Data correction	1.7
Power quality investigation and repair	2.8
Investigative / triggered maintenance	2.1
Pole / vehicle interaction	0.7
Environmental cleanup	2.3
Emergency follow-up asset replacement	0.8
Graffiti cleanup	1.1
Service order investigation issues	0.9
Other	2.5
Sub total	22.4
Total:	!E40 Is Not In Table

**Note: The values in the table above are expenditure by activity as at September 2011 (represented \$ million real at 30 June 2012)*