

LA401 Tabled Paper

(a) The completed items are as follows:

Item No.	Building	Discipline	Item Description	Contract Procurement Entity or Contractor
S.5	Site Wide Services	Electrical	Load Logging. Existing supply versus the current load demand calculations to determine whether a power upgrade is required.	Barry Allen Electrical Services Pty Ltd
A.56	Block A- Building	Mechanical	Provision of temporary infrastructure to support installing a hire chiller if failure of existing chiller was to occur.	WA Mechanical Services
S.10	Site Wide Services	Hydraulic	Replace LPG tank isolating valve.	BMW regional
Z.4	Block A - Main Hospital	Fire	Upgrade to fire doors in main hospital building as identified in Westside Fire site audit. Works include replacement of door seals, installation of fire rated vision panels and replacement of door 14 with fire rated doors.	WACHS

The items that are currently being delivered but which are not yet completed are as follows:

A.48	Block A –Main Hospital	Structural	Roof sheeting over the medical gas store room has corroded through.	WACHS
B.3	Block B – Staff Accommodation	BCA / Fire	Inadequate types of fire extinguishers installed.	WACHS
H.13	Block H - Workshop Sheds	Hydraulic	Vacuum breaker backflow vales to be installed to all hose taps.	WACHS
H.18	Block H - Workshop Sheds	Mechanical	Toilet exhaust system and kitchen fan replacement.	WACHS
H.20	Block H - Workshop Sheds	Mechanical	New structural support to the air conditioning unit supplying the Lunch Room.	WACHS
H.22	Block H - Workshop Sheds	Structural	Additional support steel beam.	WACHS
A.12	Block A - Main Hospital	Electrical	Upgrade to emergency lighting system, log books and central testing facility.	Pearmans
A.53	Block A - Main Hospital	Hydraulic	Installation of stainless steel toilet pan with Bariatric Ensuite.	Copperfield Plumbing