

ATTACHMENTS TO QON 1586

| (b) Date | (c) Outage duration | (d) Notification | (e) Cause |
|------------|------------------------|--|---|
| 28/09/2013 | 1 hour and 15 minutes | As this was an unplanned interruption due to a fault on the network, there was no notification | Cable failure at the Morley zone substation |
| 17/11/2013 | 8 hours and 27 minutes | Notification was sent to customers on the 4 November | Planned interruption to replace pole and cables |