

WOODMAN POINT WASTE WATER TREATMENT PLANT, EXPANSION

2113. Hon Jim Scott to the Minister for Government Enterprises

- (1) Are there any plans to expand the Woodman Point wastewater facility?
- (2) If yes to (1), at what stage is the proposed expansion?
- (3) What level of environmental assessment does the Water Corporation expect any proposed expansion of the Woodman Point wastewater facility will receive?
- (4) What is the current capacity of the Woodman Point wastewater facility?
- (5) What is the proposed capacity of the Woodman Point wastewater facility?
- (6) What wastewater technology will be used for any proposed expansion of the Woodman Point wastewater facility?
- (7) Are odours from the Woodman Point wastewater facility monitored?
- (8) Is wastewater from Western Australia Paper Mills or Watsonia sent to the Woodman Point wastewater facility?
- (9) If not, are there any plans to do so?

Hon NICK GRIFFITHS replied:

- (1) Yes.
- (2) Yet to be initiated.
- (3) Works Approval or Public Environmental Review.
- (4) Nominally 160ML/day.
- (5) Up to 320ML/day.
- (6) Activated Sludge and/or other appropriate technology.
- (7) Yes.
- (8) Waste water from Western Australian Paper Mills Industrial Operations is not. Watsonia directs pre-treated waste to the sewer which feeds Woodman Point.
- (9) Not at present for Western Australia Paper Mills.