

TRAIN STATIONS — PERTH — ELEVATOR WARRANTY

3152. Hon Ken Travers to the Parliamentary Secretary representing the Minister for Transport:

I refer to question on notice No. 2607 regarding the lifts at Perth rail station, and ask:

- (a) When does the warranty on these lifts expire;
- (b) Which of the breakdowns for Lift 2–13 are covered by the warranty; and
- (c) What has been the cost of all the non-warranty work on Lift 2–13?

Hon Jim Chown replied:

- (a) The warranty for the lifts expired on the following dates:

Lift 1–13: December 2014

Lift 2–13: December 2014

Lift 3–13: December 2014

Lift 4–13: August 2014

However, it should be noted that the warranty period was extended to April 2015 until the causes for some performance issues were established.

- (b) The breakdowns to lift 2–13 were covered by the warranty except on two occasions which were caused by water ingress in the lift shaft and water entering through a construction joint in the concrete shaft.
- (c) The cost associated with the non-warranty work for lift 2–13 was \$1 015.