Extract from Hansard

[COUNCIL — Wednesday, 3 December 2014] p9209c-9209c

Hon Ken Travers; Hon James Chown

TRAIN STATIONS — JOONDALUP — ESCALATORS

1760. Hon Ken Travers to the Parliamentary Secretary representing the Minister for Transport:

- (1) Since 1 January 2014, how long has the eastern escalator been out of service at the Joondalup train station, and why?
- (2) Since 1 January 2014, how long was the western escalator been out of service, and why?

Hon Jim Chown replied:

(1) From 1 January 2014, the eastern escalator was out of service at Joondalup station on the following dates and reasons described below:

12 May 2014 to 5 September 2014

The escalator was undergoing a complete replacement as it was over 20 years old and is considered life-expired.

17 October 2014

The escalator was out of service for approximately five hours due to a technical fault that occurred.

21 October 2014

The escalator was out of service for approximately six hours due to a fault with the hand rail speed sensors.

(2) From 1 January 2014, the western escalator at Joondalup station was out of service for the following dates and reasons described below:

17 March 2014 to 1 April 2014

The escalator was out of service due to a fault with a shaft bearing part that was life expired.

24 May 2014 to 27 May 2014

The escalator was out of service due to a brake coil that had burnt out. This was an obsolete part and had to be replaced.

8 September 2014

The escalator was put out of service on 8 September 2014 to commence a complete replacement as it is over 20 years old and considered to be life-expired. It is due to go back into service in mid-December 2014.